

TECHNICAL CERTIFICATE

BASORPLAST BPI

Fire Risk

BASOR ELECTRIC, S.A. **CERTIFIES** that:

- The BASORPLAST BPI system is **Non-flame propagating** according to standard UNE EN 50085 “Cable trunking systems and cable ducting systems for electrical installations”.
- The BASORPLAST BPI system is classified as **94 V-0** according to standard ANSI/UL94.
- The BASORPLAST BPI system is classified as **M1** according to standard UNE 23727 “Reaction to fire test of building materials. Classification of building materials”.



Sandra Sanchis Muñoz
Quality Responsible
Basor Electric, S.A.